



中认英泰检测技术有限公司
CQC Intime Testing Technology Co., Ltd.

UN38.3 试验概要

LITHIUM CELLS OR BATTERIES TEST SUMMARY IN ACCORDANCE WITH SUB-SECTION 38.3 OF UN MANUAL OF TESTS AND CRITERIA

NO. CQCIT2006J0189

样品描述(Sample Description):

电池名称(Cell/battery Name):

储能模组 Energy Storage Module

质量(Mass):

41 kg

规格参数(Specification Parameter):

■锂离子电池/电芯 96V 37Ah 3.552kWh

□锂金属电池/电芯 ___ V ___ Ah ___ g

物理形状(Physical Description):

长方体 Cuboid

型号(Model Numbers):

HV9637

委托单位(Applicant):

大秦新能源科技(泰州)有限公司

Daqin New Energy Tech(Taizhou)., Ltd.

泰州市姜堰区三水街道科技路 199 号

199 Keji Road ,Sanshui Street ,Jiangyan

District ,Taizhou City

0523-88510062

zhangweizhong@dyness-tech.com

www.dyness-tech.com.cn

样品生产厂商(Sample Manufacturer):

大秦新能源科技(泰州)有限公司

Daqin New Energy Tech(Taizhou)., Ltd.

泰州市姜堰区三水街道科技路 199 号

199 Keji Road ,Sanshui Street ,Jiangyan

District ,Taizhou City

0523-88510062

zhangweizhong@dyness-tech.com

www.dyness-tech.com.cn

UN38.3 测试实验室(UN38.3 Test Lab):

中认英泰检测技术有限公司

CQC Intime Testing Technology Co., Ltd.

江苏省苏州市吴中区吴中大道 1368 号东太湖科技金融城

East Taihu Technology and Finance City,

No.1368 Wuzhong Dadao Road, Wuzhong

Economic Development Zone, Suzhou, Jiangsu.

0512-66303623

cqc_jszlb@126.com

http://www.cqc-it.com

样品测试信息(Sample Test Information):

试验报告编号(Test Report Number):

20200406J06754

试验报告签发日期(Date of Test Report):

2020.06.01

所用《试验和标准手册》版本(Edition of UN Manual of Tests and Criteria Used):

《关于危险货物运输的建议书 试验和标准手册》第六版修订 1 第 38.3 节

Recommendations on the Transport of Dangerous Goods, Manual of Tests and Criteria, ST/SG/AC.10/11/Rev.6/Amend.1/Section 38.3

所进行的试验及其结果(即: 通过/未通过)一览表(List of Tests Conducted and Results(Pass/Fail)):

T1	高度模拟(Altitude simulation)	Pass
T2	温度试验(Thermal test)	Pass
T3	振动(Vibration)	Pass
T4	冲击(Shock)	Pass
T5	外部短路(External short circuit)	Pass
T6	撞击/挤压(Impact/Crush)	Pass
T7	过度充电(Overcharge)	Not Applicable
T8	强制放电(Forced discharge)	Pass

是否符合集成锂电池的测试要求(Assembled Lithium Battery Test Requirement):

□38.3.3(f) □38.3.3(g) ■不适用 N/A

赵润生

技术负责人 (Technical Leader)

签发日期 (Date of issue): 2020-06-01